

Bygningers energieffektivitet – BMS-system – Del 1: Modul M10-12

Energy performance of buildings – Building management system – Part 1: Module M10-12 (ISO 52127-1: 2021)

A large, thin, black curved line that starts at the bottom left, rises to a peak in the middle, and then descends towards the bottom right, spanning across the lower half of the page.

DANSK STANDARD
Danish Standards Association

Göteborg Plads 1
DK-2150 Nordhavn
Tel: +45 39 96 61 01
dansk.standard@ds.dk
www.ds.dk

DS/EN ISO 52127-1:2021

København

DS projekt: M338301

ICS: 91.120.10

Første del af denne publikations betegnelse er:

DS/EN ISO, hvilket betyder, at det er en international standard, der har status både som europæisk og dansk standard.

Denne publikations overensstemmelse er:

IDT med: ISO 52127-1:2021

IDT med: EN ISO 52127-1:2021

DS-publikationen er på engelsk.

Denne publikation erstatter: [DS/EN 16947-1:2017](#)

DS-publikationstyper

Dansk Standard udgiver forskellige publikationstyper.

Typen på denne publikation fremgår af forsiden.

Der kan være tale om:

Dansk standard

- standard, der er udarbejdet på nationalt niveau, eller som er baseret på et andet lands nationale standard, eller
- standard, der er udarbejdet på internationalt og/eller europæisk niveau, og som har fået status som dansk standard

DS-information

- publikation, der er udarbejdet på nationalt niveau, og som ikke har opnået status som standard, eller
- publikation, der er udarbejdet på internationalt og/eller europæisk niveau, og som ikke har fået status som standard, fx en teknisk rapport, eller
- europæisk præstandard

DS-håndbog

- samling af standarder, eventuelt suppleret med informativt materiale

DS-hæfte

- publikation med informativt materiale

Til disse publikationstyper kan endvidere udgives

- tillæg og rettelsesblade

DS-publikationsform

Publikationstyperne udgives i forskellig form som henholdsvis

- fuldtekstpublikation (publikationen er trykt i sin helhed)
- godkendelsesblad (publikationen leveres i kopi med et trykt DS-omslag)
- elektronisk (publikationen leveres på et elektronisk medie)

DS-betegnelse

Alle DS-publikationers betegnelse begynder med DS efterfulgt af et eller flere præfikser og et nr., fx **DS 383**, **DS/EN 5414** osv. Hvis der efter nr. er angivet et **A** eller **Cor**, betyder det, enten at det er et **tillæg** eller et **rettelsesblad** til hovedstandard, eller at det er indført i hovedstandard.

DS-betegnelse angives på forsiden.

Overensstemmelse med anden publikation:

Overensstemmelse kan enten være IDT, EQV, NEQ eller MOD

- **IDT:** Når publikationen er identisk med en given publikation.
- **EQV:** Når publikationen teknisk er i overensstemmelse med en given publikation, men præsentationen er ændret.
- **NEQ:** Når publikationen teknisk eller præsentationsmæssigt ikke er i overensstemmelse med en given standard, men udarbejdet på baggrund af denne.
- **MOD:** Når publikationen er modificeret i forhold til en given publikation.

EUROPEAN STANDARD

EN ISO 52127-1

NORME EUROPÉENNE

EUROPÄISCHE NORM

February 2021

ICS 91.120.10

Supersedes EN 16947-1:2017

English Version

Energy performance of buildings - Building management system - Part 1: Module M10-12 (ISO 52127-1: 2021)

Performance énergétique des bâtiments - Système de gestion technique des bâtiments - Partie 1: Module M10-12 (ISO 52127-1: 2021)

Energieeffizienz von Gebäuden - Gebäudemanagementsystem - Teil 1: Modul M10-12 (ISO 52127-1:2021)

This European Standard was approved by CEN on 18 November 2020.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

Page

European foreword	3
--------------------------------	----------

European foreword

This document ([EN ISO 52127-1:2021](#)) has been prepared by Technical Committee ISO/TC 205 "Building environment design" in collaboration with Technical Committee CEN/TC 247 "Building Automation, Controls and Building Management" the secretariat of which is held by SNV.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2021, and conflicting national standards shall be withdrawn at the latest by August 2021.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN shall not be held responsible for identifying any or all such patent rights.

This document supersedes [EN 16947-1:2017](#).

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Endorsement notice

The text of [ISO 52127-1:2021](#) has been approved by CEN as [EN ISO 52127-1:2021](#) without any modification.

INTERNATIONAL STANDARD

DS/EN ISO 52127-1:2021
ISO
52127-1

First edition
2021-02-02

**Energy performance of buildings —
Building management system —**

Part 1:
Module M10-12

*Performance énergétique des bâtiments — Système de gestion
technique des bâtiments —*

Partie 1: Module M10-12



Reference number
ISO 52127-1:2021(E)

© ISO 2021



COPYRIGHT PROTECTED DOCUMENT

© ISO 2021, Published in Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Ch. de Blandonnet 8 • CP 401
CH-1214 Vernier, Geneva, Switzerland
Tel. +41 22 749 01 11
Fax +41 22 749 09 47
copyright@iso.org
www.iso.org

Contents

	Page
Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Symbols and subscripts	2
4.1 Symbols.....	2
4.2 Subscripts.....	2
5 Description of the methods	2
5.1 Output of the method.....	2
5.2 General description of the method(s).....	3
5.3 Calculation time steps.....	3
6 BMS function 1 (management of setpoints)	4
6.1 Output data.....	4
6.2 Input data – source of data.....	4
6.3 Calculation procedure.....	5
6.3.1 Operating conditions calculation.....	5
6.3.2 Energy calculation.....	6
7 BMS function 2 (runtime management)	7
7.1 Output data.....	7
7.2 Input data.....	7
7.2.1 Source of data.....	7
7.2.2 Operating conditions.....	7
7.3 Calculation procedure.....	8
7.3.1 Operating conditions calculation.....	8
7.3.2 Energy calculation.....	8
8 BMS function 3 (sequencing of generators)	9
8.1 Output data.....	9
8.2 Input data.....	9
8.2.1 Source of data.....	9
8.2.2 Operating conditions.....	9
8.3 Calculation procedure.....	9
8.3.1 Operating conditions calculation.....	9
8.3.2 Energy calculation.....	10
9 BMS function 4 (Local energy production and renewable energies)	11
9.1 Output data.....	11
9.2 Input data – source of data.....	12
9.3 Calculation procedure – energy calculation.....	12
10 BMS function 5 (heat recovery/heat shifting)	12
10.1 Output data.....	12
10.2 Input data.....	12
10.2.1 Source of data.....	12
10.2.2 Operating conditions.....	12
11 BMS function 6 (smart grid)	12
11.1 Output data.....	12
11.2 Input data.....	13
12 Simplified input data correlations	13
13 Quality control	13

14	Compliance check	13
	Annex A (informative) Short description of BMS main functions	14
	Bibliography	15

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT) see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 205, *Building environment design*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 247, *Building Automation, Controls and Building Management*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

A list of all parts in the ISO 52127 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document is part of a series of standards aiming at international harmonization of the methodology for the assessment of the energy performance of buildings called “EPB set of standards”.

As part of the “EPB set of standards”, it complies with the requirements for the set of basic EPB documents [ISO 52000-1](#) (see Normative references), [CEN/TS 16628](#) and [CEN/TS 16629](#) (see References [4] and [5]) developed under a mandate given to CEN by the European Commission and the European Free Trade Association (Mandate M/480), and supports essential requirements of EU Directive 2010/31/EU on the energy performance of buildings (EPBD).

This document is clearly identified in the modular structure developed to ensure a transparent and coherent EPB standard set in [ISO 52000-1](#). BAC (building automation and control) is identified in the modular structure as technical building system M10. However, other standards issued by ISO TC 205 deal with control accuracy, control functions and control strategies using standards communications protocol (these last standards do not belong to the EPB standards set).

To avoid a duplication of calculation due to the BAC (avoid double impact), no calculations are done in BAC EPB standard set, but in each underlying standard of EPB set of standards (from M1 to M9 in the modular structure), an identifier, developed and presented in the M10 covered by [ISO 52120-1](#), is used where appropriate. The way of interaction is described in detail in [ISO/TR 52000-2](#) accompanying the over-arching standard. As a consequence, the Annex A and Annex B concept as Excel sheets with the calculation formulas used in the EPB standards are not applicable for this document.

The main target groups of this document are all the users of the set of EPB standards (e.g. architects, engineers, regulators).

Further target groups are parties wanting to motivate their assumptions by classifying the building energy performance for a dedicated building stock.

More information is provided in [ISO/TR 52127-2](#)^[3], the Technical Report accompanying this document.

[Table 1](#) shows the relative position of this document within the set of EPB standards in the context of the modular structure as set out in [ISO 52000-1](#).

NOTE 1 — In [ISO/TR 52000-2](#) the same table can be found, with, for each module, the numbers of the relevant EPB standards and accompanying Technical Reports that are published or in preparation.

NOTE 2 — The modules represent EPB standards, although one EPB standard can cover more than one module and one module can be covered by more than one EPB standard, for instance a simplified and a detailed method respectively.

Table 1 — Position of this document (in casu M10–12), within the modular structure of the set of EPB standards

Over-arching		Technical building system										
Sub module	Descriptions	Building (as such)	Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic hot waters	Lighting	Building automation and control	PV, wind...
sub1	M1	M2	M3	M4	M5	M6	M7	M8	M9	M10	M11	
1	General	General	General									
2	Common terms and definitions; symbols, units and subscripts	Building energy needs	Needs									
3	Application	(Free) Indoor conditions without systems	Maximum load and power									
4	Ways to express energy performance	Ways to express energy performance	Ways to express energy performance									
5	Building functions and building boundaries	Heat transfer by transmission	Emission and control									
6	Building occupancy and operating conditions	Heat transfer by infiltration and ventilation	Distribution and control									
7	Aggregation of energy services and energy carriers	Internal heat gains	Storage and control									
8	Building partitioning	Solar heat gains	Generation and control									

NOTE The shaded modules are not applicable.

Table 1 (continued)

Over-arching		Technical building system										
Sub module	Descriptions	Building (as such)	Descriptions	Heating	Cooling	Ventilation	Humidification	Dehumidification	Domestic hot waters	Lighting	Building automation and control	PV, wind...
sub1	M1	M2	M3	M4	M5	M6	M7	M8	M9	M10	M11	
9	Calculated energy performance	Building dynamics (thermal mass)	Load dispatching and operating conditions									
10	Measured energy performance	Measured energy performance	Measured energy performance									
11	Inspection	Inspection	Inspection									
12	Ways to express indoor comfort		BMS							x		
13	External environment conditions											
14 ^a	Economic calculation											

NOTE The shaded modules are not applicable.

Energy performance of buildings — Building management system —

Part 1: Module M10-12

1 Scope

This document specifies operational activities, overall alarming, fault detection and diagnostics, reporting, monitoring, energy management functions, functional interlocks and optimizations to set and maintain energy performance of buildings.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

[ISO 52000-1:2017](#), *Energy performance of buildings — Overarching EPB assessment — Part 1: General framework and procedures*

[ISO 7345:2018](#), *Thermal performance of buildings and building components — Physical quantities and definitions*

[ISO 52120-1:—](#)¹⁾, *Energy performance of buildings — Contribution of building automation and controls and building management — Part 1: Modules M10-4,5,6,7,8,9,10*

1) Under preparation. Stage at the time of publication ISO/DIS 52120-1:2021.